

**MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS**

PWS ID 0240002
PWS NAME DIBERVILLE W/S
COUNTY HARRISON
SAMPLE POINT LC0002

COLLECTOR
LAB
WORKORDER
LAB ID

OCCUPANT
 MSDH LAB
 PB-240816-031

SAMPLE TYPE
COLLECTED
RECEIVED
COMPOSITED

PBCU
 2024-08-15 15:30
 2024-08-16
 NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm		2024-09-13 10:39
1022	COPPER, FREE	200.8	0.0137 ppm	1.3 ppm		2024-09-13 10:39

Comments: 3Y2022/ COLLECTED BY: UNKNOWN/ CHAIN OF CUSTODY NOT FILLED OUT COMPLETELY

**MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS**

PWS ID 0240002
PWS NAME DIBERVILLE W/S
COUNTY HARRISON
SAMPLE POINT LC0004

COLLECTOR
LAB MSDH LAB
WORKORDER
LAB ID PB-240816-032

SAMPLE TYPE
COLLECTED 2024-08-15 05:00
RECEIVED 2024-08-16
COMPOSITED NO

PBCU
 2024-08-15 05:00
 2024-08-16
 NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.015 ppm		2024-09-13 10:39
1022	COPPER, FREE	200.8	0.0315 ppm	1.3 ppm		2024-09-13 10:39

Comments: 3Y2022/ COLLECTED BY: UNKNOWN/ CHAIN OF CUSTODY NOT FILLED OUT COMPLETELY

**MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS**

PWS ID 0240002
PWS NAME DIBERVILLE W/S
COUNTY HARRISON
SAMPLE POINT LC0007

COLLECTOR
LAB MSDH LAB
WORKORDER
LAB ID PB-240816-033

SAMPLE TYPE PBCU
COLLECTED 2024-08-15 05:30
RECEIVED 2024-08-16
COMPOSITED NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.015 ppm		2024-09-13 10:39
1022	COPPER, FREE	200.8	0.0301 ppm	1.3 ppm		2024-09-13 10:39

Comments: 3Y2022/ COLLECTED BY: UNKNOWN/ CHAIN OF CUSTODY NOT FILLED OUT COMPLETELY

**MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS**

PWS ID 0240002
PWS NAME DIBERVILLE W/S
COUNTY HARRISON
SAMPLE POINT LC0010

COLLECTOR
LAB MSDH LAB
WORKORDER
LAB ID PB-240816-034

OCCUPANT
MSDH LAB

SAMPLE TYPE PBCU
COLLECTED 2024-08-15 08:10
RECEIVED 2024-08-16
COMPOSITED NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.015 ppm		2024-09-13 10:39
1022	COPPER, FREE	200.8	0.0292 ppm	1.3 ppm		2024-09-13 10:39

Comments: 3Y2022/ COLLECTED BY: UNKNOWN/ CHAIN OF CUSTODY NOT FILLED OUT COMPLETELY

**MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS**

PWS ID 0240002
PWS NAME DIBERVILLE W/S
COUNTY HARRISON
SAMPLE POINT DS000

COLLECTOR
LAB MSDH LAB
WORKORDER
LAB ID PB-240816-035

SAMPLE TYPE
COLLECTED 2024-08-15 07:30
RECEIVED 2024-08-16
COMPOSITED NO

PBCU
 2024-08-15 07:30
 2024-08-16
 NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm		2024-09-13 10:39
1022	COPPER, FREE	200.8	0.0481 ppm	1.3 ppm		2024-09-13 10:39

Comments: 3Y2022/ COLLECTED BY: UNKNOWN/ SITE#: 014 (NOT IN SYSTEM)/ CHAIN OF CUSTODY NOT FILLED OUT COMPLETELY

**MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS**

PWS ID 0240002
PWS NAME DIBERVILLE W/S
COUNTY HARRISON
SAMPLE POINT LC0016

COLLECTOR
LAB
WORKORDER
LAB ID

OCCUPANT
 MSDH LAB
 PB-240816-036

SAMPLE TYPE
COLLECTED
RECEIVED
COMPOSITED

PBCU
 2024-08-15 06:24
 2024-08-16
 NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.015 ppm		2024-09-13 10:39
1022	COPPER, FREE	200.8	0.0194 ppm	1.3 ppm		2024-09-13 10:39

Comments: 3Y2022/ COLLECTED BY: UNKNOWN/ CHAIN OF CUSTODY NOT FILLED OUT COMPLETELY

**MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS**

PWS ID 0240002
PWS NAME DIBERVILLE W/S
COUNTY HARRISON
SAMPLE POINT LC0023

COLLECTOR
LAB
WORKORDER
LAB ID

OCCUPANT
MSDH LAB
PB-240816-037

SAMPLE TYPE PBCU
COLLECTED 2024-08-15 05:40
RECEIVED 2024-08-16
COMPOSITED NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.015 ppm		2024-09-13 10:39
1022	COPPER, FREE	200.8	0.0337 ppm	1.3 ppm		2024-09-13 10:39

Comments: 3Y2022/ COLLECTED BY: UNKNOWN/ CHAIN OF CUSTODY NOT FILLED OUT COMPLETELY

**MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS**

PWS ID 0240002
PWS NAME DIBERVILLE W/S
COUNTY HARRISON
SAMPLE POINT LC0024

COLLECTOR
LAB
WORKORDER
LAB ID

OCCUPANT
MSDH LAB
PB-240816-038

SAMPLE TYPE
COLLECTED
RECEIVED
COMPOSITED

PBCU
2024-08-15 09:00
2024-08-16
NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.015 ppm		2024-09-13 10:39
1022	COPPER, FREE	200.8	0.0079 ppm	1.3 ppm		2024-09-13 10:39

Comments: 3Y2022/ COLLECTED BY: UNKNOWN/ CHAIN OF CUSTODY NOT FILLED OUT COMPLETELY

**MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS**

PWS ID 0240002
PWS NAME DIBERVILLE W/S
COUNTY HARRISON
SAMPLE POINT LC0036

COLLECTOR
LAB MSDH LAB
WORKORDER
LAB ID PB-240816-039

SAMPLE TYPE
COLLECTED 2024-08-15 11:30
RECEIVED 2024-08-16
COMPOSITED NO

PBCU

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0014 ppm	0.015 ppm		2024-09-13 10:39
1022	COPPER, FREE	200.8	0.0177 ppm	1.3 ppm		2024-09-13 10:39

Comments: 3Y2022 "COLL BY: UNKNOWN" "CHAIN OF CUSTODY IS NOT COMPLETELY FILLED OUT"

**MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS**

PWS ID 0240002
PWS NAME DIBERVILLE W/S
COUNTY HARRISON
SAMPLE POINT LC0034

COLLECTOR
LAB
WORKORDER
LAB ID

OCCUPANT
MSDH LAB
PB-240816-040

SAMPLE TYPE
COLLECTED
RECEIVED
COMPOSITED

PBCU
2024-08-15 10:30
2024-08-16
NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm		2024-09-13 10:39
1022	COPPER, FREE	200.8	0.0146 ppm	1.3 ppm		2024-09-13 10:39

Comments: 3Y2022 "COLL BY: UNKNOWN" "CHAIN OF CUSTODY IS NOT COMPLETELY FILLED OUT"